

ADDENDUM
PAGE 1 OF 1

OWNER:	Ann Arbor Downtown Development Authority 415 North Fifth Avenue, 2nd Floor Ann Arbor, MI 48104
ENGINEER:	Fishbeck 750 Trade Centre Way, Suite 200 Kalamazoo, MI 49008
DRAWING REVISION NO.:	A2
ISSUED HEREWITH:	
SPECIFICATION SECTIONS:	None
SHEETS:	None
BIDS DUE:	May 21, 2026, 2:00 p.m. (EDT)

This Addendum is issued to all Bid Set Holders, is a part of the Contract Documents, and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid form; failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Section: 07 95 16 – Expansion Joint Systems for Parking Structures (not reissued)

- A. Delete Paragraph 2.3.F as follows:
Reviewed Preformed Expanding Foam Expansion Joint Systems – Horizontal, Non-Traffic Bearing.
1. Horizontal Colorseal, Sika Emseal, Westborough, MA.
 2. Or reviewed equal.
- B. Add Paragraph 2.3.F as follows:
Reviewed Preformed Expanding Foam Expansion Joint Systems – Horizontal, Traffic Bearing.
1. DSM System, Sika Emseal, Westborough, MA.
 2. Iso-Flex Precom H-SL, LymTal International, Inc., Orion, MI.
 3. Or reviewed equal.

ITEM NO. 2:

Section: 09 97 33 – Elastomeric Coating Systems (not reissued)

- A. Revised the warranty duration indicated in Paragraph 1.7.F – Warranty Duration as follows:
1. Bid price shall include a 5-year installer warranty and a 10-year manufacturer warranty commencing with the date of project acceptance in accordance with the General Conditions, and Division 01 Section “Closeout Procedures.”

QUESTIONS:

- A. Can Lymtal Precom C be added to the Expanding Foam Expansion Joint Systems Spec?
Response: *Preformed Expanding Foam Expansion Joint Systems – Horizontal, Non-Traffic Bearing was revised to traffic bearing; refer to Item No. 1 above for revised products.*
- B. Can the elastomeric coating warranty be changed to a 5-year labor and 10-year material manufacturer warranty?
Response: *Yes, refer to Item No. 2 above.*
- C. For Detail 7/SR504, what size area should be included for concrete replacement?
Response: *Concrete replacement should span from tee-to-tee, a length of approximately 4 feet, with a minimum width to provide the detailed wash around drain. Verify all dimensions in field prior to construction.*

END OF ADDENDUM